

# C\_comp in IBIS

Walter Katz

SiSoft


IBIS-ATM June 9, 2015

# IBIS Describes How to Hook Up C\_comp When Deriving IV Curves

- For example, the following pictures on page 61 (in IBIS 6.0) relate to the method of “Data Collection” to determine the models IV curves.



# IBIS 5.1 Incorrectly Replaced GND with GND Symbol



\* Note: More advanced package parameters are available within this standard, including more detailed power and ground net descriptions.

# IBIS Describes How to Hook Up C\_comp\_\* When Simulating

IBIS 6.0 page 32:


C\_comp\_pullup, C\_comp\_pulldown, C\_comp\_power\_clamp, and C\_comp\_gnd\_clamp are intended to represent the parasitic capacitances of those structures whose I-V characteristics are described by the [Pullup], [Pulldown], [POWER Clamp] and [GND Clamp] I-V tables. For this reason, the simulator should generate a circuit netlist so that, if defined, each of the C\_comp\_\* capacitors are connected in parallel with their corresponding I-V tables, whether or not the I-V table exists. That is, the C\_comp\_\* capacitors are positioned between the signal pad and the nodes defined by the [Pullup Reference], [Pulldown Reference], [POWER Clamp Reference] and [GND Clamp Reference] keywords, or the [Voltage Range] keyword and GND.

# IBIS Does not Describe How to Hook Up C\_comp When Simulating

- Cannot give a reference page because there is none.
- On page 70 it leaves it up to the simulator
  - All tables assume that the die capacitance is included. Potential numerical problems associated with processing the data using the effective C\_comp (or C\_comp\_\* values as appropriate) for effective die capacitance may be handled differently among simulators.

# Correct Picture of the Terminator Model for Simulation

|<-----TERMINATOR Model----->|



# Connecting C\_comp to Node 0 is Wrong

- Results are significantly different when simulating with C\_comp connected between model pad and Node 0 and between model pad and A\_pdref when A\_pdref is connected to a power delivery network.

# Conclusion

IBIS should do one of the following:

1. Recommend that model makers use C\_comp\_\* instead of C\_comp. (Informative).
2. Recommend (or require?) that EDA tools connect C\_comp to A\_pdref, or split C\_comp between A\_pdref and A\_puref. (Informative or Normative).